

A photograph of the University of Washington Molecular Engineering & Sciences Building at dusk. The building is a modern structure with a combination of light-colored stone and large glass panels. The interior lights are on, and the building is illuminated from within. In the foreground, there is a large, rectangular, blue-tinted glass structure that appears to be a skylight or a decorative element. The sky is a deep blue with some clouds. The overall scene is a professional architectural presentation.

University of Washington Molecular Engineering & Sciences Building: Integrated Design for Natural Ventilation

Chris Flint Chatto
ZGF Architects LLP

*Association of Professional
Energy Managers*

3 | 16 | 2018

Project Context

- > Unique aspects of this project: client, location, program

Problem

- > Incorporating natural ventilation in offices of a laboratory building
- > Design process
- > Local climate
- > Applicable standards and codes

Solution

- > Building organization
- > Load reduction
- > Facade development
- > Related mechanical systems
- > Projecting performance

Conclusions

- > Phase change material performance
- > Occupant satisfaction
- > Energy and carbon savings
- > Cost impacts

Sustainability Ratings

- GOLD rated campus (STARS)
- Rated in top 10 U.S. Universities in Sustainability (Sierra Cool Schools, 2016)

Sustainability Accomplishments

- Salmon Safe Campus
- 15% reduction in GHG since 2015

Sustainability Practices

- 31 UW LEED-Certified Projects
- 13 UW Registered Projects (certification pending)
- LEED Silver is mandated for all state-funded University of Washington major projects.



UW Carbon Initiatives & Building Stock

Signatory to the American College and University Presidents
Climate Commitment in March 2007.

Performed an inventory of greenhouse gas emissions
attributable to the University.

Developing a carbon reduction plan.

Operates over 20 million gross square feet of space.

Owns 527 buildings, leases 175 another at 3 campuses
and numerous field facilities.

48% of the total square footage on the Seattle Campus is air-
conditioned, with laboratories and classrooms commonly
being air-conditioned.

Office space is approximately 25% of all space on campus,
and is the largest single category of space.




Project Goals

Provide instrumentation space to support future high sensitivity measurement in the rapidly evolving field of molecular engineering;

Address campus needs for modern lab space as research requirements for advanced labs have expanded faster than the current infrastructure can support;

House flexible research lab spaces designed to bring different fields together attracting eight new interdisciplinary faculty hires to join approximately 30 other faculty from bioengineering, chemical engineering, electrical engineering, materials science and engineering, biochemistry, chemistry, and microbiology.



Energy Conservation Measures:

1. Natural ventilation

2. Optimized laboratory/fume hood VAV System, including:

- reduced laboratory ACH rates
- low flow VAV fume hoods
- occupied/unoccupied controls
- chilled beams where feasible

3. High performance windows and optimized shading


4. Daylighting/efficient electric lighting



5. Heat recovery from process chiller

6. Dynamic laboratory stack exhaust, under study

7. Maximum efficiency pumping, with:


- variable flow hydronic systems with pressure independent valves






Project Location

CONTEXT



Existing Site

CONTEXT



CONTEXT

Site Plan Phase One

CONTEXT



CONTEXT

Science Courtyard

CONTEXT

Weather

Building Structure

Lab/Office Program

Willing Client

Energy Intensive

Load Reduction Capable

Life Cycle Cost Driven Solutions

Lab Ventilation Energy Burden on Office System

Characteristics Related to Natural Ventilation

CONTEXT

Energy: Reduced energy use

Costs: Reduced operating costs
Reduced construction costs

Reliability: Reduced mechanical systems


Occupants: Increased satisfaction and productivity
of building occupants

Climate: Opportunities presented by Pacific NW
climate

	Schematic Design	Design Development	Construction Documents
Process	<ul style="list-style-type: none"> • Conceive natural ventilation approach • Apply experience to arrive at concept 	<ul style="list-style-type: none"> • Define criteria for evaluation ASHRAE CIBSE • Educate the UW • Earn UW buy-in • Natural ventilation charrette • Establish impact to first cost 	<ul style="list-style-type: none"> • Refine design: apertures, thermal mass, wind, solar, and mechanical assists • Determine energy savings • Life-cycle cost analysis
Tools	<ul style="list-style-type: none"> • Climate tools (temperature, wind) 	<ul style="list-style-type: none"> • Energy model (define peak loads) • Single-zone bulk air flow model • Ecotect (facade insolation) 	<ul style="list-style-type: none"> • CFD/multi-zone air flow model • Energy model (overall energy use) • Spreadsheets (cost analysis)


Process of Design

PROBLEM




Annual Temperature – TMY3 Seattle Boeing

PROBLEM



Annual Temperature – TMY3 & Campus ATG Building

PROBLEM




Annual Temperature Bins

PROBLEM


Cumulative hours exceeding temperature

Data sources: UW ATG building and TMY3




Annual Temperature – TMY3 & Campus ATG Building

PROBLEM



Local Wind Data

PROBLEM




Local Wind Data

PROBLEM

FUNCTION	CRITERIA
1. Temperature control	(68°F-83°F)
2. Ventilation ASHRAE / Seattle Building Code LEED EQ C2	4% operable window area of zone floor area
3. Acoustical performance	Separation from vehicle noise
4. Lab/office separation	Containment control of lab air


ASHRAE Comfort Range for Mechanically Cooled Spaces



Traditional Comfort Range

PROBLEM


ASHRAE Comfort Range for Naturally Conditioned Spaces



Adaptive Comfort Range

PROBLEM

ASHRAE Comfort Range for Naturally Conditioned Spaces




Comfort Range Comparison

PROBLEM

ASHRAE Comfort Range for Naturally Conditioned Spaces


Adaptive Comfort and Temperature Percentile Analysis



Adaptive Comfort Range



PROBLEM

1. Program orientation within building
2. Single sided vs. double-sided ventilation
3. Lab separation
4. Others



Conceptual Considerations

SOLUTION



Lab – Office Morphologies

SOLUTION




Lab – Office Morphologies

SOLUTION



Scheme 1: office on west



ADVANTAGES


- + Uses prevailing breezes from NW/SW to drive ventilation (greater airflow, greater capacity for cooling)
- + Lab equipment less impacted from vibrations from buses

DISADVANTAGES


- Noise & dirt from buses may impact offices
- Greater solar gain on W/SW orientations may work against natural ventilation



Scheme 2: office on east



Nonoperable windows of labs might be better fit for noisier, dirtier western edge. Structure may need to be reinforced for additional vibration control.




Orient stack outlet away from prevailing wind to create greater suction to drive stack effect. Solar gain might also be used to create heat differential and further induce air flow. Stack may need to be taller and/or fan assisted to compensate for lack of breezes from the east.

ADVANTAGES

- + Offices more protected from noise and dirt of busses
- + E/NE orientation of offices reduces heat from solar gain

DISADVANTAGES

- E/NE orientation of offices reduces potential of using prevailing winds to drive natural ventilation (must rely on stack effect alone, opening sizes and/or stack height must be increased to compensate)



Lab – Office Boundary

SOLUTION

Developing System Components

Load reduction


Facade development

Chimney configuration

Aperture size

Exposing building mass (insulation of slab)


Peak load: July 10th, 10am (Temp = 73F)




Load Reduction

SOLUTION

Analysis Grid
RAD Daylight Factors
View Range: 0.0 - 10.0 %DF
© 2007 ECOTECT v10



Daylight factor (%)





Target illum. (fc)	Daylight factor		Avg over space
	3.4	0.9	
30	75.9	26.9%	51.4%
20	87.9	40.3%	64.1%

(vs. 75% goal)

Reducing Electric Light Usage Through Daylighting



SOLUTION



option A1
 AREA: 10' x 7'
 AREA: 70' x 70' x 70'
 100%

GLAZING AREA:
 EXTERNAL SHADING:
 OPERABLE WINDOW SIZE:



14' high, 41.6% opaque
 none
 2'-7" x 8'-3"
 (estimated 4.2 sf open area)



option A2
 AREA: 10' x 7'
 AREA: 70' x 70' x 70'
 100%

GLAZING AREA:
 EXTERNAL SHADING:
 OPERABLE WINDOW SIZE:



14' high, 30% opaque
 5'-2" no-2 shades 18" apart
 2'-7" x 10'-4"
 (estimated 5.3 sf open area)



option A3
 AREA: 10' x 7'
 AREA: 70' x 70' x 70'
 100%

GLAZING AREA:
 EXTERNAL SHADING:
 OPERABLE WINDOW SIZE:

14' high, 30% opaque
 none
 2'-7" x 10'-4"
 (estimated 5.3 sf open area)



option A4
 AREA: 10' x 7'
 AREA: 70' x 70' x 70'
 100%

GLAZING AREA:
 EXTERNAL SHADING:
 OPERABLE WINDOW SIZE:

14' high, 45.5% opaque
 none
 5'-7" x 5'-5"
 (estimated 3.4 sf open area)

Façade Development

SOLUTION

Facade opacity

40.8% red.

Glass type

34.1% red.


Overhangs

51.6% red.

Total

81.1% reduction

(vs. 81.7% goal)




Reducing Solar Gain

SOLUTION




SOLUTION




Stack Ventilation Variables

SOLUTION





Stack Ventilation Scheme

SOLUTION



Stack Performance: Single Zone Model

SOLUTION



LEVEL 1

AREA: 25.5 SF (12.75 x 2)
HEIGHT: 62'-0"

LEVEL 2


AREA: 39.12 SF (19.56 x 2)
HEIGHT: 46'-0"

LEVEL 3

AREA: 34.22 SF (17.11 x 2)
HEIGHT: 30'-0"

Actual Stack Areas and Heights


SOLUTION



Stack Performance: Single Zone Model

SOLUTION

All year




Predicted fan use:

Total hours: 33


Peak need: 7.3 btu/hr/F

Avg need: 2.1 btu/hr/SF

Summer




Fortnight




2nd Floor Single Zone Model

SOLUTION



Operable Window Strategy

SOLUTION



Operable Window Strategy

SOLUTION



Each floor has 16 windows:

	# Windows	Effective SF
Mechanically actuated	8	40.6
Human operated	8	40.6

Facade

SOLUTION

TYPICAL OFFICE LEVEL FLOORPLAN



1 Follow red + green lights

- The windows are user controlled and should only be opened when the **green** indicator light is illuminated.
- Closing the windows when the **red** light is illuminated will result in additional energy savings and increased thermal comfort.
- Close windows when you leave for the day.

2 Adjust the blinds

- Raise and lower the blinds, and rotate the blades in order to exclude direct sun.
- To maximize daylight and electric light dimming, open the blinds when the direct sun is no longer causing discomfort.

3 Utilize light + fan controls

- Electric lights are zoned to turn lights on only when needed and automatically dim or turn lights off in areas that are adequately daylit.
- To use the ceiling fans, hold the fan switch for 5 seconds, to allow building automation system and fan controls to communicate.

Occupant control strategies


SOLUTION

1. 500 CFM supply air from lab system
2. Thermal transfer through lab/office boundary
3. Mechanical assist for chimneys
4. Ceiling fans
5. Night flush of thermal mass



Additional Cooling Features

SOLUTION




Preliminary Macro-Flow Interior Temp. Results

SOLUTION

The floor plan shows a building layout with a grid system. The horizontal axis is labeled 1 through 8, and the vertical axis is labeled A through D. Rooms include a Conference Room (top left), Reception (top center), Research Lab (center left), and several Offices (center right). Red dots indicate the locations of ceiling fans. An arrow points from the text 'Ceiling Fan' to one of these red dots in the central corridor area.

SOLUTION




BioPCM™ phase change material

BioPCM™ Mats	Unit	23C/73F			27C/81F		
		.56 lb/sq. ft.	1 lb/sq. ft.	2 lb/sq. ft.	.56 lb/sq. ft.	1 lb/sq. ft.	2 lb/sq. ft.
Thickness	mm	14	14	14	14	14	14
Weight per square foot	lb	0.77	1.32	2.66	0.78	1.31	2.66
Total unit thickness	mm	.25-.35	.4-.6	1	.25-.35	.4-.6	1
Dimensions	mm/ft	418.1/16.5	418.1/16.5	418.1/16.5	418.1/16.5	418.1/16.5	418.1/16.5
Energy Store values - Other temperature ranges are available							
PCM loading	%	73%	76%	75%	74%	76%	75%
Melt point*	°C/°F	23/73	23/73	23/73	27/81	27/81	27/81
Latent heat storage capacity	J/g >	200	200	200	200	210	210
Boiling Point	°C	>240.0	>240.0	>240.0	>240.0	>240.0	>240.0

Phase change material

SOLUTION

Heating Condition



Phase change material

SOLUTION



Thermal mass


SOLUTION

WIND-DRIVEN TURBINE
EXHAUST WITH BACKUP
ELECTRIC MOTOR

AUXILIARY LOUVERS

INSULATED GLASS IN
METAL FRAME

INSULATED
METAL WALL
PANELS



SCALE: 1'-0"

Assists: Sun, Wind, Fan

SOLUTION





Assists: Sun, Wind, Fan

SOLUTION

- > Phase change material
- > Thermal comfort
- > Energy Savings
- > Carbon Footprint Evaluation
- > Cost




Jul 22	Jul 23	Jul 24	Jul 25	Jul 26
High 79° Low 56°	High 88° Low 57°	High 88° Low 58°	High 88° Low 55°	High 87° Low 58°




PCM effectiveness

CONCLUSION


CBE Post Occupancy Survey Results (% occupants satisfied)




In warm/hot weather, the temperature in my workspace is: (check all that apply)



In cool/cold weather, the temperature in my workspace is: (check all that apply)




When is this most often a problem? (check all that apply)



Thermal comfort


CONCLUSION



Energy Savings vs Typical

CONCLUSION

Estimated Office Natural Ventilation Savings



Energy Savings

CONCLUSION

Natural Ventilation Reduces CO₂ by 44 Metric Tons

What does this mean?


103 barrels of oil burned per yearor

8 cars on the roador

5,039 gallons of gasoline being consumed.

Carbon Savings

CONCLUSION



Cost Impacts & Net Effect of Natural Ventilation

CONCLUSION

Not Easy to Implement

Requires:

Committed Team

Integrated Design

Aggressive Load Reduction

Educated Occupants

Integrated Team:

ZGF Architects LLP

Affiliated Engineers, Inc.

University of Washington

SOLARC Architecture and Engineering
(Energy modeling & early natural ventilation concepts)

Seattle City Light
(local utility, helped fund energy model and provides energy conservation incentives)

Hoffman Construction
(contractor, provided cost estimation)

Summary

CONCLUSION

Chris Flint Chatto
ZGF Architects LLP
chris.chatto@zgf.com



CONCLUSION